GOVERNMENT OF ANDHRA PRADESH
ABSTRACT

Energy, Infrastructure & Investment Department – The Electricity Act, 2003 – Regulation 36 of Central Electricity Authority (Measures Relating to Safety and Electric Supply) Regulations, 2010 – Provisions for Supply and Use of Electricity in Multi-Storied Buildings more than 15 metres in height – Notification – Issued.

ENERGY (Power.II) DEPARTMENT

G.O.MS.No. 10 Dated: 03-05-2017
Read the following:

G.O.Ms.No.42, Energy(Services) Department,dated:19.11.2011

ORDER:

NOTIFICATION

In supersession of the earlier G.O's issued on the above subject and in exercise of the powers conferred by the Regulation 36 of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations,2010, the State Government hereby specifies that all installations of Voltage of Supply Exceeding 11KV at the Point of Commencement of supply (irrespective of connected load) of Multi-Storied Buildings of more than Fifteen (15) Metres in height, shall be inspected by the Electrical Inspector.

For Industries, Chief Electrical Inspector to Government (CEIG) inspection shall only be for voltage levels of 132 KV and above.

(BY ORDER AND IN THE NAME OF THE GOVERNOR OF ANDHRA PRADESH)

AJAY JAIN
PRINCIPAL SECRETARY TO GOVERNMENT

To
The Commissioner of Printing and Stationery, Vijayawada
(With a request to publish the G.O. in the extraordinary issue of Andhra Pradesh Gazette and supply 50 copies to this Department)
The Director of Electrical Safety and Chief Electrical Inspector to Government,
2nd Floor, 1/16, Brodipet, GUNTUR-522002.(for necessary action)
Copy to:-
The Principal Secretary to Hon'ble Chief Minister.
The P.S. to Hon'ble Minister, Energy.
The Principal Secretary to Government(Industries).
The Advisor to Principal Secretary to Government,
Energy, I&I Department, APTRANSCO, Vidyut Soudha, Hyderabad.
The Chairman & Managing Director,
Andhra Pradesh Transmission Corporation Limited(APTRANSCO), Hyderabad.
The Chairman & Managing Director,
Andhra Pradesh Southern Power Distribution Company Limited(APSPDCL),
Vidyuth Nilayam, D.No.19-13-65/A, Srinivasapuram, TIRUPATI.
The Chairman & Managing Director,
Andhra Pradesh Eastern Power Distribution Company Limited(APEPDCL),
P&T Colony, Seethamadhara, Visakhapatnam.
The P.S. to Principal Secretary to Government, Energy, I&I Department.
SF/SC.

//FORWARDED BY ORDER//

SECTION OFFICER